



CERTIFICATE OF ANALYSIS

Customer : Strategic Environmental
25 Butternut Lane
Bayville, NJ 08721

Project ID : Red Bank Reg. H.S., 101 Ridge Road
PAS Project ID : P21-13055

Matrix : Drinking Water
Report Date : 12/10/2021

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P21-13055-01	First Draw HS 101-5 Spigot	Lead	5.00	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/7/21 07:48	12/8/21 15:53
P21-13055-02	Flush HS 101-5 Spigot	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/7/21 07:48	12/8/21 15:57

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Mark D. Feitelson, Lab. Director



Specialists in Drinking Water Testing Technologies • Residential • Industrial • Municipal

PRECISION ANALYTICAL SERVICES, INC.

2181 WHITEVILLE ROAD TOMBS RIVER, NJ 08755 PHONE 732-914-1515 FAX 732-914-1816

CHAIN OF CUSTODY

Customer: Strategic Environmental
 Address: 25 Butternut Lane
 Bayville, NJ 08701
 Phone: (732) 539-7342

School Name: Red Bank Rea HS
 School Address: 101 Bridge Road
 Sampled By: [Signature]
 Print Name: [Signature]
 RESULTS TO: lbonses@aol.com

Sample ID Location	Date: / / Time Sampled	Matrix Code	Grab or Comp	Flush Sample	Filter Present	# Containers	Glass or Plastic	Analyses	LAB ID
First Draw HS101-5 Spigot	7:48	DW	Grab			1	250 ml Plastic	Lead	P21-P3055-01
Flush HS101-5 Spigot	7:48	DW	Grab			1	250 ml Plastic	Lead	" 02
		DW	Grab			1	250 ml Plastic	Lead	
*Retest Location # 39		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	

SAMPLES REC'D UNPRESERVED. PRESERVED IN LAB.

Page 1 of 1

Deliverables: PDF Std. PDF Reduc. PDF Full EDD

Date/Time Preserved with HNO3: 12/1/21 @ 9:45am

MATRIX CODES: GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

PRESERVATIVE CODES: 0 = Ice 1 = HCl 2 = H2SO4 3 = NaOH 4 = HNO3 5 = Other

	Print Name:	Signature:	Company:	Date + Time
Relinquished:	J. Boushara	[Signature]	PAS	12/1/21
Received:	Lynn Souza	[Signature]	PAS	9:30 AM
Relinquished:				
Received:				
Relinquished:				
Received:				